

February 2015, Draft 00

## **22 1116 – Domestic Water Piping**

### **PART 1. - GENERAL**

#### **Domestic Water Inside Supply Pipe**

- 2.5” or less - Type L copper. No-lead solder or grooved fittings.
- 3” or more - Ordinary duty weight galvanized steel. Flanged or grooved fittings.
- Stainless steel ball Isolation valves on all branches off domestic mains.

**This section of the NIU Design Requirements establishes minimum requirements only.**

**It should not be used as a complete specification.**